

HELIUM LEAK DETECTION TEST

TC No.: HLD/A9/K/HQ/048/25	Model No.: KFKHQ-9	Date: 19-11-2025
Type and Capacity of Extinguisher	: KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFKHQ9 048/25	
Batch Quantity	: 10 Nos.	
Serial Numbers	: 00471 To 480	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
471	Pass	472	Pass	473	Pass	474	Pass
475	Pass	476	Pass	477	Pass	478	Pass
479	Pass	480	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory