

# HYDRO PRESSURE TEST

|                                   |                                                          |                  |
|-----------------------------------|----------------------------------------------------------|------------------|
| TC No.: HPT/F9/SP/RQ/035/26       | Model No.: KFMSRQ-9                                      | Date: 16-05-2026 |
| Type and Capacity of Extinguisher | : KFMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr. |                  |
| Batch Number                      | : KFMSRQ9 035/26                                         |                  |
| Batch Quantity                    | : 101.00 Nos.                                            |                  |
| Serial Numbers                    | : 03401 To 3500 And 3405A                                |                  |
| Month of Manufacturing            | : May/26                                                 |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 3405A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 3401                                                         | Pass   | 3402     | Pass   | 3403     | Pass   | 3404     | Pass   |
| 3405                                                         | Pass   | 3406     | Pass   | 3407     | Pass   | 3408     | Pass   |
| 3409                                                         | Pass   | 3410     | Pass   | 3411     | Pass   | 3412     | Pass   |
| 3413                                                         | Pass   | 3414     | Pass   | 3415     | Pass   | 3416     | Pass   |
| 3417                                                         | Pass   | 3418     | Pass   | 3419     | Pass   | 3420     | Pass   |
| 3421                                                         | Pass   | 3422     | Pass   | 3423     | Pass   | 3424     | Pass   |
| 3425                                                         | Pass   | 3426     | Pass   | 3427     | Pass   | 3428     | Pass   |
| 3429                                                         | Pass   | 3430     | Pass   | 3431     | Pass   | 3432     | Pass   |
| 3433                                                         | Pass   | 3434     | Pass   | 3435     | Pass   | 3436     | Pass   |
| 3437                                                         | Pass   | 3438     | Pass   | 3439     | Pass   | 3440     | Pass   |
| 3441                                                         | Pass   | 3442     | Pass   | 3443     | Pass   | 3444     | Pass   |
| 3445                                                         | Pass   | 3446     | Pass   | 3447     | Pass   | 3448     | Pass   |
| 3449                                                         | Pass   | 3450     | Pass   | 3451     | Pass   | 3452     | Pass   |
| 3453                                                         | Pass   | 3454     | Pass   | 3455     | Pass   | 3456     | Pass   |
| 3457                                                         | Pass   | 3458     | Pass   | 3459     | Pass   | 3460     | Pass   |
| 3461                                                         | Pass   | 3462     | Pass   | 3463     | Pass   | 3464     | Pass   |
| 3465                                                         | Pass   | 3466     | Pass   | 3467     | Pass   | 3468     | Pass   |
| 3469                                                         | Pass   | 3470     | Pass   | 3471     | Pass   | 3472     | Pass   |
| 3473                                                         | Pass   | 3474     | Pass   | 3475     | Pass   | 3476     | Pass   |
| 3477                                                         | Pass   | 3478     | Pass   | 3479     | Pass   | 3480     | Pass   |
| 3481                                                         | Pass   | 3482     | Pass   | 3483     | Pass   | 3484     | Pass   |
| 3485                                                         | Pass   | 3486     | Pass   | 3487     | Pass   | 3488     | Pass   |
| 3489                                                         | Pass   | 3490     | Pass   | 3491     | Pass   | 3492     | Pass   |
| 3493                                                         | Pass   | 3494     | Pass   | 3495     | Pass   | 3496     | Pass   |
| 3497                                                         | Pass   | 3498     | Pass   | 3499     | Pass   | 3500     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**