

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/038/26	Model No.: KMCRQ-5	Date: 14-05-2026
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 038/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 01851 To 1900	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01851 To 1900 and removed from the Lot/Batch							
1851	Pass	1852	Pass	1853	Pass	1854	Pass
1855	Pass	1856	Pass	1857	Pass	1858	Pass
1859	Pass	1860	Pass	1861	Pass	1862	Pass
1863	Pass	1864	Pass	1865	Pass	1866	Pass
1867	Pass	1868	Pass	1869	Pass	1870	Pass
1871	Pass	1872	Pass	1873	Pass	1874	Pass
1875	Pass	1876	Pass	1877	Pass	1878	Pass
1879	Pass	1880	Pass	1881	Pass	1882	Pass
1883	Pass	1884	Pass	1885	Pass	1886	Pass
1887	Pass	1888	Pass	1889	Pass	1890	Pass
1891	Pass	1892	Pass	1893	Pass	1894	Pass
1895	Pass	1896	Pass	1897	Pass	1898	Pass
1899	Pass	1900	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory