

## HELIUM LEAK DETECTION TEST

|                                   |                                                                       |                  |
|-----------------------------------|-----------------------------------------------------------------------|------------------|
| TC No.: HLD/KF/LI/HQ9/016/26      | Model No.: KFLIHQ-9                                                   | Date: 18-05-2026 |
| Type and Capacity of Extinguisher | : KFLIHQ-9-Lithium-Ion (AVD) Stored Pressure Fire Extinguisher 9 Ltr. |                  |
| Batch Number                      | : KFLIHQ9 016/26                                                      |                  |
| Batch Quantity                    | : 10 Nos.                                                             |                  |
| Serial Numbers                    | : 00151 To 160                                                        |                  |
| Month of Manufacturing            | : May/26                                                              |                  |

| Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|----------|--------|----------|--------|----------|--------|----------|--------|
| 151      | Pass   | 152      | Pass   | 153      | Pass   | 154      | Pass   |
| 155      | Pass   | 156      | Pass   | 157      | Pass   | 158      | Pass   |
| 159      | Pass   | 160      | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of  $1 \times 10^{-6}$  mbar.l/sec and no any cylinders shows leakage beyond this limit.



**Authorized Signatory**