

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/082/26	Model No.: KMCRQ-10	Date: 15-06-2026
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 082/26	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00811 To 820	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00811 To 820 and removed from the Lot/Batch							
811	Pass	812	Pass	813	Pass	814	Pass
815	Pass	816	Pass	817	Pass	818	Pass
819	Pass	820	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory