

HYDRO PRESSURE TEST

TC No.: HPT/A3/K/HQ/002/26	Model No.: KFKHQ-3	Date: 27-01-2026
Type and Capacity of Extinguisher	: KFKHQ-3-Kanex F Class Kitchen Fire Extinguisher Cap. 3 Ltr.	
Batch Number	: KFKHQ3 002/26	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00011 To 20 And 15A	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 15A and removed from the Lot/Batch							
11	Pass	12	Pass	13	Pass	14	Pass
15	Pass	16	Pass	17	Pass	18	Pass
19	Pass	20	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory