

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/127/26	Model No.: KFARQ-6-90%	Date: 16-05-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 127/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 12601 To 12700 And 12605A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 12605A and removed from the Lot/Batch							
12601	Pass	12602	Pass	12603	Pass	12604	Pass
12605	Pass	12606	Pass	12607	Pass	12608	Pass
12609	Pass	12610	Pass	12611	Pass	12612	Pass
12613	Pass	12614	Pass	12615	Pass	12616	Pass
12617	Pass	12618	Pass	12619	Pass	12620	Pass
12621	Pass	12622	Pass	12623	Pass	12624	Pass
12625	Pass	12626	Pass	12627	Pass	12628	Pass
12629	Pass	12630	Pass	12631	Pass	12632	Pass
12633	Pass	12634	Pass	12635	Pass	12636	Pass
12637	Pass	12638	Pass	12639	Pass	12640	Pass
12641	Pass	12642	Pass	12643	Pass	12644	Pass
12645	Pass	12646	Pass	12647	Pass	12648	Pass
12649	Pass	12650	Pass	12651	Pass	12652	Pass
12653	Pass	12654	Pass	12655	Pass	12656	Pass
12657	Pass	12658	Pass	12659	Pass	12660	Pass
12661	Pass	12662	Pass	12663	Pass	12664	Pass
12665	Pass	12666	Pass	12667	Pass	12668	Pass
12669	Pass	12670	Pass	12671	Pass	12672	Pass
12673	Pass	12674	Pass	12675	Pass	12676	Pass
12677	Pass	12678	Pass	12679	Pass	12680	Pass
12681	Pass	12682	Pass	12683	Pass	12684	Pass
12685	Pass	12686	Pass	12687	Pass	12688	Pass
12689	Pass	12690	Pass	12691	Pass	12692	Pass
12693	Pass	12694	Pass	12695	Pass	12696	Pass
12697	Pass	12698	Pass	12699	Pass	12700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory