



Warranty Certificate

Date: 18-07-2026

Manufacturer: Kanex Fire Solutions Limited.

Customer Name: Red Elemental-I Pvt. Ltd.

Warranty Start Date: 18-07-2026

Warranty End Date: 17-07-2027.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	2	As Per Annexure – I
2	KMCRRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	5	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice **No. 26-27/B/000137 Dated: 18-07-2026 P.O.No. 1254-117** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.



Authorized Signatory

