

DOC NUMBER		DESCRIPTION		
QD006		2.2 Test report		
INDEX	MODIFICATION (BRIEF DESCRIPTION)	DATE OF CHANGE	CHANGED BY (INITIALS)	
-	creation	27/06/18	CM	

Certificate of Compliance EN 10204-2.2			
Supplier: Fire Automatique Innovations S.a.r.l			
Customer : Kanex Fire Solutions Limited			
Order no.: PO#17891		Order confirmation:	
Delivery note : 2026-20952		2025-40529	
Description	Article no.:	Customers reference:	Quantity
End of Line Adapter	V1023011	F1040012	2313
Perfomed tests			Results
Function test : 18bar -> ok			ok
Tightness : Helium leakage test : 18 Bar < 1 x 10 -5 mbar * l / sec (100 % Helium)			ok

Gauge connection thread	M10 x 1
Tube connection	Ø6mm
Customer Marking	KANEX
Lot number	X6082

We confirm that the above product is compliant with the ordered goods	ok
--	-----------

Date: 01.04.2026	Name: Th.Agethen	Signature: 
-------------------------	-------------------------	--