

HELIUM LEAK DETECTION TEST

TC No.: HLD/KF/LI/HQ4/003/26

Model No.: KFLIHQ-4

Date: 09-03-2026

Type and Capacity of Extinguisher : KFLIHQ-4-Lithium-Ion (AVD) Stored Pressure Fire Extinguisher 4 Ltr.

Batch Number : KFLIHQ4 003/26

Batch Quantity : 10 Nos.

Serial Numbers : 00021 To 30

Month of Manufacturing : Mar/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
21	Pass	22	Pass	23	Pass	24	Pass
25	Pass	26	Pass	27	Pass	28	Pass
29	Pass	30	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**