

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/168/26	Model No.: KFARQ-6-50%	Date: 16-05-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 168/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 16701 To 16800 And 16705A	
Month of Manufacturing	: May/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 16705A and removed from the Lot/Batch							
16701	Pass	16702	Pass	16703	Pass	16704	Pass
16705	Pass	16706	Pass	16707	Pass	16708	Pass
16709	Pass	16710	Pass	16711	Pass	16712	Pass
16713	Pass	16714	Pass	16715	Pass	16716	Pass
16717	Pass	16718	Pass	16719	Pass	16720	Pass
16721	Pass	16722	Pass	16723	Pass	16724	Pass
16725	Pass	16726	Pass	16727	Pass	16728	Pass
16729	Pass	16730	Pass	16731	Pass	16732	Pass
16733	Pass	16734	Pass	16735	Pass	16736	Pass
16737	Pass	16738	Pass	16739	Pass	16740	Pass
16741	Pass	16742	Pass	16743	Pass	16744	Pass
16745	Pass	16746	Pass	16747	Pass	16748	Pass
16749	Pass	16750	Pass	16751	Pass	16752	Pass
16753	Pass	16754	Pass	16755	Pass	16756	Pass
16757	Pass	16758	Pass	16759	Pass	16760	Pass
16761	Pass	16762	Pass	16763	Pass	16764	Pass
16765	Pass	16766	Pass	16767	Pass	16768	Pass
16769	Pass	16770	Pass	16771	Pass	16772	Pass
16773	Pass	16774	Pass	16775	Pass	16776	Pass
16777	Pass	16778	Pass	16779	Pass	16780	Pass
16781	Pass	16782	Pass	16783	Pass	16784	Pass
16785	Pass	16786	Pass	16787	Pass	16788	Pass
16789	Pass	16790	Pass	16791	Pass	16792	Pass
16793	Pass	16794	Pass	16795	Pass	16796	Pass
16797	Pass	16798	Pass	16799	Pass	16800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory