



CYRUS INDIA SECURITIES PVT. LTD.

QC Report of 24V Master Control Units

To,

KANEX FIRE SOLUTIONS LTD.

Fire & Safety Solutions

Plot No. 7-8, Paras Industrial Estate,

Near Garibshapir Dargah, Sihor, Gujarat – 364240

GSTIN / UIN: 24AACCK4417C1Z3

Dear Sir / Madam,

24V Master control units with batch number 50nos are shown below along with the report.

QC report is mentioned below: -

24V Master Control Units (Batch No: SABB00000721)		
S No	QC Point	Checked Points
1	Print as per client requirements	Ok
2	Power Cable	Ok
3	SMPS	Ok
4	SMPS output voltage	Ok
5	Battery Charging output voltage	Ok
6	Inner Connectors attached properly	Ok
7	Zone Naming	Ok
8	All Zone working	Ok
9	Hooter Working	Ok
10	Sensors working when attached to zones	Ok
11	Glue Pasting done properly	Ok
12	LED Working	Ok
13	LCD Working	Ok
14	Panel Paint quality	Ok
15	Panel Metal and finishing quality	Ok
16	Screw	Ok
17	Soldering done properly	Ok
18	Wiring covered properly	Ok
19	Fix Outer Connectors and Stick Sticker with Connection name	Ok
20	Main Key Switch proper working	Ok
21	All IC Fixed properly	Ok

Thanking you.

For Cyrus India Securities Pvt. Ltd.

Authorized Signatory

B-44/69, Sector-Q, Aliganj, Lucknow - 226024

Phone : 0522-4026916, 2746916 Fax : 0522-4075916 | Email : info@siriusecms.in

Website : www.cyrusindia.com