

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/042/26

Model No.: KFKHQ-6

Date: 24-03-2026

Type and Capacity of Extinguisher : KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.

Batch Number : KFKHQ6 042/26

Batch Quantity : 10 Nos.

Serial Numbers : 00411 To 420

Month of Manufacturing : Mar/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
411	Pass	412	Pass	413	Pass	414	Pass
415	Pass	416	Pass	417	Pass	418	Pass
419	Pass	420	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**