

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A40/RQ/146/26     | Model No.: MARQ-6-50%                                          | Date: 21-03-2026 |
| Type and Capacity of Extinguisher | : MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ50%6 146/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 14501 To 14600 And 14505A                                    |                  |
| Month of Manufacturing            | : Mar/26                                                       |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 14505A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 14501                                                         | Pass   | 14502    | Pass   | 14503    | Pass   | 14504    | Pass   |
| 14505                                                         | Pass   | 14506    | Pass   | 14507    | Pass   | 14508    | Pass   |
| 14509                                                         | Pass   | 14510    | Pass   | 14511    | Pass   | 14512    | Pass   |
| 14513                                                         | Pass   | 14514    | Pass   | 14515    | Pass   | 14516    | Pass   |
| 14517                                                         | Pass   | 14518    | Pass   | 14519    | Pass   | 14520    | Pass   |
| 14521                                                         | Pass   | 14522    | Pass   | 14523    | Pass   | 14524    | Pass   |
| 14525                                                         | Pass   | 14526    | Pass   | 14527    | Pass   | 14528    | Pass   |
| 14529                                                         | Pass   | 14530    | Pass   | 14531    | Pass   | 14532    | Pass   |
| 14533                                                         | Pass   | 14534    | Pass   | 14535    | Pass   | 14536    | Pass   |
| 14537                                                         | Pass   | 14538    | Pass   | 14539    | Pass   | 14540    | Pass   |
| 14541                                                         | Pass   | 14542    | Pass   | 14543    | Pass   | 14544    | Pass   |
| 14545                                                         | Pass   | 14546    | Pass   | 14547    | Pass   | 14548    | Pass   |
| 14549                                                         | Pass   | 14550    | Pass   | 14551    | Pass   | 14552    | Pass   |
| 14553                                                         | Pass   | 14554    | Pass   | 14555    | Pass   | 14556    | Pass   |
| 14557                                                         | Pass   | 14558    | Pass   | 14559    | Pass   | 14560    | Pass   |
| 14561                                                         | Pass   | 14562    | Pass   | 14563    | Pass   | 14564    | Pass   |
| 14565                                                         | Pass   | 14566    | Pass   | 14567    | Pass   | 14568    | Pass   |
| 14569                                                         | Pass   | 14570    | Pass   | 14571    | Pass   | 14572    | Pass   |
| 14573                                                         | Pass   | 14574    | Pass   | 14575    | Pass   | 14576    | Pass   |
| 14577                                                         | Pass   | 14578    | Pass   | 14579    | Pass   | 14580    | Pass   |
| 14581                                                         | Pass   | 14582    | Pass   | 14583    | Pass   | 14584    | Pass   |
| 14585                                                         | Pass   | 14586    | Pass   | 14587    | Pass   | 14588    | Pass   |
| 14589                                                         | Pass   | 14590    | Pass   | 14591    | Pass   | 14592    | Pass   |
| 14593                                                         | Pass   | 14594    | Pass   | 14595    | Pass   | 14596    | Pass   |
| 14597                                                         | Pass   | 14598    | Pass   | 14599    | Pass   | 14600    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**