

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/073/26	Model No.: KFARQ-4-90%	Date: 22-03-2026
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 073/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 07201 To 7300 And 7205A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 7205A and removed from the Lot/Batch							
7201	Pass	7202	Pass	7203	Pass	7204	Pass
7205	Pass	7206	Pass	7207	Pass	7208	Pass
7209	Pass	7210	Pass	7211	Pass	7212	Pass
7213	Pass	7214	Pass	7215	Pass	7216	Pass
7217	Pass	7218	Pass	7219	Pass	7220	Pass
7221	Pass	7222	Pass	7223	Pass	7224	Pass
7225	Pass	7226	Pass	7227	Pass	7228	Pass
7229	Pass	7230	Pass	7231	Pass	7232	Pass
7233	Pass	7234	Pass	7235	Pass	7236	Pass
7237	Pass	7238	Pass	7239	Pass	7240	Pass
7241	Pass	7242	Pass	7243	Pass	7244	Pass
7245	Pass	7246	Pass	7247	Pass	7248	Pass
7249	Pass	7250	Pass	7251	Pass	7252	Pass
7253	Pass	7254	Pass	7255	Pass	7256	Pass
7257	Pass	7258	Pass	7259	Pass	7260	Pass
7261	Pass	7262	Pass	7263	Pass	7264	Pass
7265	Pass	7266	Pass	7267	Pass	7268	Pass
7269	Pass	7270	Pass	7271	Pass	7272	Pass
7273	Pass	7274	Pass	7275	Pass	7276	Pass
7277	Pass	7278	Pass	7279	Pass	7280	Pass
7281	Pass	7282	Pass	7283	Pass	7284	Pass
7285	Pass	7286	Pass	7287	Pass	7288	Pass
7289	Pass	7290	Pass	7291	Pass	7292	Pass
7293	Pass	7294	Pass	7295	Pass	7296	Pass
7297	Pass	7298	Pass	7299	Pass	7300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory