

HYDRO PRESSURE TEST

TC No.: HPT/A2/A90/RQ/092/25	Model No.: KFARQ-2-90%	Date: 10-11-2025
Type and Capacity of Extinguisher	: KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KFARQ90%2 092/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 09101 To 9200 And 9105A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 9105A and removed from the Lot/Batch							
9101	Pass	9102	Pass	9103	Pass	9104	Pass
9105	Pass	9106	Pass	9107	Pass	9108	Pass
9109	Pass	9110	Pass	9111	Pass	9112	Pass
9113	Pass	9114	Pass	9115	Pass	9116	Pass
9117	Pass	9118	Pass	9119	Pass	9120	Pass
9121	Pass	9122	Pass	9123	Pass	9124	Pass
9125	Pass	9126	Pass	9127	Pass	9128	Pass
9129	Pass	9130	Pass	9131	Pass	9132	Pass
9133	Pass	9134	Pass	9135	Pass	9136	Pass
9137	Pass	9138	Pass	9139	Pass	9140	Pass
9141	Pass	9142	Pass	9143	Pass	9144	Pass
9145	Pass	9146	Pass	9147	Pass	9148	Pass
9149	Pass	9150	Pass	9151	Pass	9152	Pass
9153	Pass	9154	Pass	9155	Pass	9156	Pass
9157	Pass	9158	Pass	9159	Pass	9160	Pass
9161	Pass	9162	Pass	9163	Pass	9164	Pass
9165	Pass	9166	Pass	9167	Pass	9168	Pass
9169	Pass	9170	Pass	9171	Pass	9172	Pass
9173	Pass	9174	Pass	9175	Pass	9176	Pass
9177	Pass	9178	Pass	9179	Pass	9180	Pass
9181	Pass	9182	Pass	9183	Pass	9184	Pass
9185	Pass	9186	Pass	9187	Pass	9188	Pass
9189	Pass	9190	Pass	9191	Pass	9192	Pass
9193	Pass	9194	Pass	9195	Pass	9196	Pass
9197	Pass	9198	Pass	9199	Pass	9200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory