

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/013/26

Model No.: KMCRQ-10

Date: 08-02-2026

Type and Capacity of Extinguisher : KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.

Batch Number : KMCRQ10 013/26

Batch Quantity : 10.00 Nos.

Serial Numbers : 00121 To 130

Month of Manufacturing : Feb/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
----------	--------	----------	--------	----------	--------	----------	--------

Burst test conducted on 00121 To 130 and removed from the Lot/Batch

121	Pass	122	Pass	123	Pass	124	Pass
125	Pass	126	Pass	127	Pass	128	Pass
129	Pass	130	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.

**Authorized Signatory**