

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A50/RQ/032/26	Model No.: MARQ-4-50%	Date: 20-03-2026
Type and Capacity of Extinguisher	: MARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: MARQ50%4 032/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 03101 To 3200 And 3105A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 3105A and removed from the Lot/Batch							
3101	Pass	3102	Pass	3103	Pass	3104	Pass
3105	Pass	3106	Pass	3107	Pass	3108	Pass
3109	Pass	3110	Pass	3111	Pass	3112	Pass
3113	Pass	3114	Pass	3115	Pass	3116	Pass
3117	Pass	3118	Pass	3119	Pass	3120	Pass
3121	Pass	3122	Pass	3123	Pass	3124	Pass
3125	Pass	3126	Pass	3127	Pass	3128	Pass
3129	Pass	3130	Pass	3131	Pass	3132	Pass
3133	Pass	3134	Pass	3135	Pass	3136	Pass
3137	Pass	3138	Pass	3139	Pass	3140	Pass
3141	Pass	3142	Pass	3143	Pass	3144	Pass
3145	Pass	3146	Pass	3147	Pass	3148	Pass
3149	Pass	3150	Pass	3151	Pass	3152	Pass
3153	Pass	3154	Pass	3155	Pass	3156	Pass
3157	Pass	3158	Pass	3159	Pass	3160	Pass
3161	Pass	3162	Pass	3163	Pass	3164	Pass
3165	Pass	3166	Pass	3167	Pass	3168	Pass
3169	Pass	3170	Pass	3171	Pass	3172	Pass
3173	Pass	3174	Pass	3175	Pass	3176	Pass
3177	Pass	3178	Pass	3179	Pass	3180	Pass
3181	Pass	3182	Pass	3183	Pass	3184	Pass
3185	Pass	3186	Pass	3187	Pass	3188	Pass
3189	Pass	3190	Pass	3191	Pass	3192	Pass
3193	Pass	3194	Pass	3195	Pass	3196	Pass
3197	Pass	3198	Pass	3199	Pass	3200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory