

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/035/26	Model No.: KMCRQ-5	Date: 26-04-2026
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 035/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 01701 To 1750	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01701 To 1750 and removed from the Lot/Batch							
1701	Pass	1702	Pass	1703	Pass	1704	Pass
1705	Pass	1706	Pass	1707	Pass	1708	Pass
1709	Pass	1710	Pass	1711	Pass	1712	Pass
1713	Pass	1714	Pass	1715	Pass	1716	Pass
1717	Pass	1718	Pass	1719	Pass	1720	Pass
1721	Pass	1722	Pass	1723	Pass	1724	Pass
1725	Pass	1726	Pass	1727	Pass	1728	Pass
1729	Pass	1730	Pass	1731	Pass	1732	Pass
1733	Pass	1734	Pass	1735	Pass	1736	Pass
1737	Pass	1738	Pass	1739	Pass	1740	Pass
1741	Pass	1742	Pass	1743	Pass	1744	Pass
1745	Pass	1746	Pass	1747	Pass	1748	Pass
1749	Pass	1750	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory