

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/034/26	Model No.: KMCRQ-5	Date: 26-04-2026
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 034/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 01651 To 1700	
Month of Manufacturing	: Apr/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01651 To 1700 and removed from the Lot/Batch							
1651	Pass	1652	Pass	1653	Pass	1654	Pass
1655	Pass	1656	Pass	1657	Pass	1658	Pass
1659	Pass	1660	Pass	1661	Pass	1662	Pass
1663	Pass	1664	Pass	1665	Pass	1666	Pass
1667	Pass	1668	Pass	1669	Pass	1670	Pass
1671	Pass	1672	Pass	1673	Pass	1674	Pass
1675	Pass	1676	Pass	1677	Pass	1678	Pass
1679	Pass	1680	Pass	1681	Pass	1682	Pass
1683	Pass	1684	Pass	1685	Pass	1686	Pass
1687	Pass	1688	Pass	1689	Pass	1690	Pass
1691	Pass	1692	Pass	1693	Pass	1694	Pass
1695	Pass	1696	Pass	1697	Pass	1698	Pass
1699	Pass	1700	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory