

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A40/RQ/071/26     | Model No.: MARQ-6-40%                                          | Date: 23-03-2026 |
| Type and Capacity of Extinguisher | : MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ40%6 071/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 07001 To 7100 And 7005A                                      |                  |
| Month of Manufacturing            | : Mar/26                                                       |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 7005A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 7001                                                         | Pass   | 7002     | Pass   | 7003     | Pass   | 7004     | Pass   |
| 7005                                                         | Pass   | 7006     | Pass   | 7007     | Pass   | 7008     | Pass   |
| 7009                                                         | Pass   | 7010     | Pass   | 7011     | Pass   | 7012     | Pass   |
| 7013                                                         | Pass   | 7014     | Pass   | 7015     | Pass   | 7016     | Pass   |
| 7017                                                         | Pass   | 7018     | Pass   | 7019     | Pass   | 7020     | Pass   |
| 7021                                                         | Pass   | 7022     | Pass   | 7023     | Pass   | 7024     | Pass   |
| 7025                                                         | Pass   | 7026     | Pass   | 7027     | Pass   | 7028     | Pass   |
| 7029                                                         | Pass   | 7030     | Pass   | 7031     | Pass   | 7032     | Pass   |
| 7033                                                         | Pass   | 7034     | Pass   | 7035     | Pass   | 7036     | Pass   |
| 7037                                                         | Pass   | 7038     | Pass   | 7039     | Pass   | 7040     | Pass   |
| 7041                                                         | Pass   | 7042     | Pass   | 7043     | Pass   | 7044     | Pass   |
| 7045                                                         | Pass   | 7046     | Pass   | 7047     | Pass   | 7048     | Pass   |
| 7049                                                         | Pass   | 7050     | Pass   | 7051     | Pass   | 7052     | Pass   |
| 7053                                                         | Pass   | 7054     | Pass   | 7055     | Pass   | 7056     | Pass   |
| 7057                                                         | Pass   | 7058     | Pass   | 7059     | Pass   | 7060     | Pass   |
| 7061                                                         | Pass   | 7062     | Pass   | 7063     | Pass   | 7064     | Pass   |
| 7065                                                         | Pass   | 7066     | Pass   | 7067     | Pass   | 7068     | Pass   |
| 7069                                                         | Pass   | 7070     | Pass   | 7071     | Pass   | 7072     | Pass   |
| 7073                                                         | Pass   | 7074     | Pass   | 7075     | Pass   | 7076     | Pass   |
| 7077                                                         | Pass   | 7078     | Pass   | 7079     | Pass   | 7080     | Pass   |
| 7081                                                         | Pass   | 7082     | Pass   | 7083     | Pass   | 7084     | Pass   |
| 7085                                                         | Pass   | 7086     | Pass   | 7087     | Pass   | 7088     | Pass   |
| 7089                                                         | Pass   | 7090     | Pass   | 7091     | Pass   | 7092     | Pass   |
| 7093                                                         | Pass   | 7094     | Pass   | 7095     | Pass   | 7096     | Pass   |
| 7097                                                         | Pass   | 7098     | Pass   | 7099     | Pass   | 7100     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**