

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/134/26	Model No.: KFARQ-4-90%	Date: 16-06-2026
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 134/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 13301 To 13400 And 13305A	
Month of Manufacturing	: Jun/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 13305A and removed from the Lot/Batch							
13301	Pass	13302	Pass	13303	Pass	13304	Pass
13305	Pass	13306	Pass	13307	Pass	13308	Pass
13309	Pass	13310	Pass	13311	Pass	13312	Pass
13313	Pass	13314	Pass	13315	Pass	13316	Pass
13317	Pass	13318	Pass	13319	Pass	13320	Pass
13321	Pass	13322	Pass	13323	Pass	13324	Pass
13325	Pass	13326	Pass	13327	Pass	13328	Pass
13329	Pass	13330	Pass	13331	Pass	13332	Pass
13333	Pass	13334	Pass	13335	Pass	13336	Pass
13337	Pass	13338	Pass	13339	Pass	13340	Pass
13341	Pass	13342	Pass	13343	Pass	13344	Pass
13345	Pass	13346	Pass	13347	Pass	13348	Pass
13349	Pass	13350	Pass	13351	Pass	13352	Pass
13353	Pass	13354	Pass	13355	Pass	13356	Pass
13357	Pass	13358	Pass	13359	Pass	13360	Pass
13361	Pass	13362	Pass	13363	Pass	13364	Pass
13365	Pass	13366	Pass	13367	Pass	13368	Pass
13369	Pass	13370	Pass	13371	Pass	13372	Pass
13373	Pass	13374	Pass	13375	Pass	13376	Pass
13377	Pass	13378	Pass	13379	Pass	13380	Pass
13381	Pass	13382	Pass	13383	Pass	13384	Pass
13385	Pass	13386	Pass	13387	Pass	13388	Pass
13389	Pass	13390	Pass	13391	Pass	13392	Pass
13393	Pass	13394	Pass	13395	Pass	13396	Pass
13397	Pass	13398	Pass	13399	Pass	13400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory