

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A2/A90/RQ/027/26      | Model No.: KFARQ-2-90%                                          | Date: 02-06-2026 |
| Type and Capacity of Extinguisher | : KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg. |                  |
| Batch Number                      | : KFARQ90%2 027/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 02601 To 2700 And 2605A                                       |                  |
| Month of Manufacturing            | : Jun/26                                                        |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 2605A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 2601                                                         | Pass   | 2602     | Pass   | 2603     | Pass   | 2604     | Pass   |
| 2605                                                         | Pass   | 2606     | Pass   | 2607     | Pass   | 2608     | Pass   |
| 2609                                                         | Pass   | 2610     | Pass   | 2611     | Pass   | 2612     | Pass   |
| 2613                                                         | Pass   | 2614     | Pass   | 2615     | Pass   | 2616     | Pass   |
| 2617                                                         | Pass   | 2618     | Pass   | 2619     | Pass   | 2620     | Pass   |
| 2621                                                         | Pass   | 2622     | Pass   | 2623     | Pass   | 2624     | Pass   |
| 2625                                                         | Pass   | 2626     | Pass   | 2627     | Pass   | 2628     | Pass   |
| 2629                                                         | Pass   | 2630     | Pass   | 2631     | Pass   | 2632     | Pass   |
| 2633                                                         | Pass   | 2634     | Pass   | 2635     | Pass   | 2636     | Pass   |
| 2637                                                         | Pass   | 2638     | Pass   | 2639     | Pass   | 2640     | Pass   |
| 2641                                                         | Pass   | 2642     | Pass   | 2643     | Pass   | 2644     | Pass   |
| 2645                                                         | Pass   | 2646     | Pass   | 2647     | Pass   | 2648     | Pass   |
| 2649                                                         | Pass   | 2650     | Pass   | 2651     | Pass   | 2652     | Pass   |
| 2653                                                         | Pass   | 2654     | Pass   | 2655     | Pass   | 2656     | Pass   |
| 2657                                                         | Pass   | 2658     | Pass   | 2659     | Pass   | 2660     | Pass   |
| 2661                                                         | Pass   | 2662     | Pass   | 2663     | Pass   | 2664     | Pass   |
| 2665                                                         | Pass   | 2666     | Pass   | 2667     | Pass   | 2668     | Pass   |
| 2669                                                         | Pass   | 2670     | Pass   | 2671     | Pass   | 2672     | Pass   |
| 2673                                                         | Pass   | 2674     | Pass   | 2675     | Pass   | 2676     | Pass   |
| 2677                                                         | Pass   | 2678     | Pass   | 2679     | Pass   | 2680     | Pass   |
| 2681                                                         | Pass   | 2682     | Pass   | 2683     | Pass   | 2684     | Pass   |
| 2685                                                         | Pass   | 2686     | Pass   | 2687     | Pass   | 2688     | Pass   |
| 2689                                                         | Pass   | 2690     | Pass   | 2691     | Pass   | 2692     | Pass   |
| 2693                                                         | Pass   | 2694     | Pass   | 2695     | Pass   | 2696     | Pass   |
| 2697                                                         | Pass   | 2698     | Pass   | 2699     | Pass   | 2700     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**