

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/205/26	Model No.: MARQ-6-40%	Date: 12-07-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 205/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 20401 To 20500 And 20405A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 20405A and removed from the Lot/Batch							
20401	Pass	20402	Pass	20403	Pass	20404	Pass
20405	Pass	20406	Pass	20407	Pass	20408	Pass
20409	Pass	20410	Pass	20411	Pass	20412	Pass
20413	Pass	20414	Pass	20415	Pass	20416	Pass
20417	Pass	20418	Pass	20419	Pass	20420	Pass
20421	Pass	20422	Pass	20423	Pass	20424	Pass
20425	Pass	20426	Pass	20427	Pass	20428	Pass
20429	Pass	20430	Pass	20431	Pass	20432	Pass
20433	Pass	20434	Pass	20435	Pass	20436	Pass
20437	Pass	20438	Pass	20439	Pass	20440	Pass
20441	Pass	20442	Pass	20443	Pass	20444	Pass
20445	Pass	20446	Pass	20447	Pass	20448	Pass
20449	Pass	20450	Pass	20451	Pass	20452	Pass
20453	Pass	20454	Pass	20455	Pass	20456	Pass
20457	Pass	20458	Pass	20459	Pass	20460	Pass
20461	Pass	20462	Pass	20463	Pass	20464	Pass
20465	Pass	20466	Pass	20467	Pass	20468	Pass
20469	Pass	20470	Pass	20471	Pass	20472	Pass
20473	Pass	20474	Pass	20475	Pass	20476	Pass
20477	Pass	20478	Pass	20479	Pass	20480	Pass
20481	Pass	20482	Pass	20483	Pass	20484	Pass
20485	Pass	20486	Pass	20487	Pass	20488	Pass
20489	Pass	20490	Pass	20491	Pass	20492	Pass
20493	Pass	20494	Pass	20495	Pass	20496	Pass
20497	Pass	20498	Pass	20499	Pass	20500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory