

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/276/26	Model No.: MARQ-6-50%	Date: 09-07-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 276/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 27501 To 27600 And 27505A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 27505A and removed from the Lot/Batch							
27501	Pass	27502	Pass	27503	Pass	27504	Pass
27505	Pass	27506	Pass	27507	Pass	27508	Pass
27509	Pass	27510	Pass	27511	Pass	27512	Pass
27513	Pass	27514	Pass	27515	Pass	27516	Pass
27517	Pass	27518	Pass	27519	Pass	27520	Pass
27521	Pass	27522	Pass	27523	Pass	27524	Pass
27525	Pass	27526	Pass	27527	Pass	27528	Pass
27529	Pass	27530	Pass	27531	Pass	27532	Pass
27533	Pass	27534	Pass	27535	Pass	27536	Pass
27537	Pass	27538	Pass	27539	Pass	27540	Pass
27541	Pass	27542	Pass	27543	Pass	27544	Pass
27545	Pass	27546	Pass	27547	Pass	27548	Pass
27549	Pass	27550	Pass	27551	Pass	27552	Pass
27553	Pass	27554	Pass	27555	Pass	27556	Pass
27557	Pass	27558	Pass	27559	Pass	27560	Pass
27561	Pass	27562	Pass	27563	Pass	27564	Pass
27565	Pass	27566	Pass	27567	Pass	27568	Pass
27569	Pass	27570	Pass	27571	Pass	27572	Pass
27573	Pass	27574	Pass	27575	Pass	27576	Pass
27577	Pass	27578	Pass	27579	Pass	27580	Pass
27581	Pass	27582	Pass	27583	Pass	27584	Pass
27585	Pass	27586	Pass	27587	Pass	27588	Pass
27589	Pass	27590	Pass	27591	Pass	27592	Pass
27593	Pass	27594	Pass	27595	Pass	27596	Pass
27597	Pass	27598	Pass	27599	Pass	27600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory