

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/277/26	Model No.: MARQ-6-50%	Date: 12-07-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 277/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 27601 To 27700 And 27605A	
Month of Manufacturing	: Jul/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 27605A and removed from the Lot/Batch							
27601	Pass	27602	Pass	27603	Pass	27604	Pass
27605	Pass	27606	Pass	27607	Pass	27608	Pass
27609	Pass	27610	Pass	27611	Pass	27612	Pass
27613	Pass	27614	Pass	27615	Pass	27616	Pass
27617	Pass	27618	Pass	27619	Pass	27620	Pass
27621	Pass	27622	Pass	27623	Pass	27624	Pass
27625	Pass	27626	Pass	27627	Pass	27628	Pass
27629	Pass	27630	Pass	27631	Pass	27632	Pass
27633	Pass	27634	Pass	27635	Pass	27636	Pass
27637	Pass	27638	Pass	27639	Pass	27640	Pass
27641	Pass	27642	Pass	27643	Pass	27644	Pass
27645	Pass	27646	Pass	27647	Pass	27648	Pass
27649	Pass	27650	Pass	27651	Pass	27652	Pass
27653	Pass	27654	Pass	27655	Pass	27656	Pass
27657	Pass	27658	Pass	27659	Pass	27660	Pass
27661	Pass	27662	Pass	27663	Pass	27664	Pass
27665	Pass	27666	Pass	27667	Pass	27668	Pass
27669	Pass	27670	Pass	27671	Pass	27672	Pass
27673	Pass	27674	Pass	27675	Pass	27676	Pass
27677	Pass	27678	Pass	27679	Pass	27680	Pass
27681	Pass	27682	Pass	27683	Pass	27684	Pass
27685	Pass	27686	Pass	27687	Pass	27688	Pass
27689	Pass	27690	Pass	27691	Pass	27692	Pass
27693	Pass	27694	Pass	27695	Pass	27696	Pass
27697	Pass	27698	Pass	27699	Pass	27700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory