

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A40/RQ/131/26     | Model No.: MARQ-6-50%                                          | Date: 15-03-2026 |
| Type and Capacity of Extinguisher | : MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ50%6 131/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 13001 To 13100 And 13005A                                    |                  |
| Month of Manufacturing            | : Mar/26                                                       |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 13005A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 13001                                                         | Pass   | 13002    | Pass   | 13003    | Pass   | 13004    | Pass   |
| 13005                                                         | Pass   | 13006    | Pass   | 13007    | Pass   | 13008    | Pass   |
| 13009                                                         | Pass   | 13010    | Pass   | 13011    | Pass   | 13012    | Pass   |
| 13013                                                         | Pass   | 13014    | Pass   | 13015    | Pass   | 13016    | Pass   |
| 13017                                                         | Pass   | 13018    | Pass   | 13019    | Pass   | 13020    | Pass   |
| 13021                                                         | Pass   | 13022    | Pass   | 13023    | Pass   | 13024    | Pass   |
| 13025                                                         | Pass   | 13026    | Pass   | 13027    | Pass   | 13028    | Pass   |
| 13029                                                         | Pass   | 13030    | Pass   | 13031    | Pass   | 13032    | Pass   |
| 13033                                                         | Pass   | 13034    | Pass   | 13035    | Pass   | 13036    | Pass   |
| 13037                                                         | Pass   | 13038    | Pass   | 13039    | Pass   | 13040    | Pass   |
| 13041                                                         | Pass   | 13042    | Pass   | 13043    | Pass   | 13044    | Pass   |
| 13045                                                         | Pass   | 13046    | Pass   | 13047    | Pass   | 13048    | Pass   |
| 13049                                                         | Pass   | 13050    | Pass   | 13051    | Pass   | 13052    | Pass   |
| 13053                                                         | Pass   | 13054    | Pass   | 13055    | Pass   | 13056    | Pass   |
| 13057                                                         | Pass   | 13058    | Pass   | 13059    | Pass   | 13060    | Pass   |
| 13061                                                         | Pass   | 13062    | Pass   | 13063    | Pass   | 13064    | Pass   |
| 13065                                                         | Pass   | 13066    | Pass   | 13067    | Pass   | 13068    | Pass   |
| 13069                                                         | Pass   | 13070    | Pass   | 13071    | Pass   | 13072    | Pass   |
| 13073                                                         | Pass   | 13074    | Pass   | 13075    | Pass   | 13076    | Pass   |
| 13077                                                         | Pass   | 13078    | Pass   | 13079    | Pass   | 13080    | Pass   |
| 13081                                                         | Pass   | 13082    | Pass   | 13083    | Pass   | 13084    | Pass   |
| 13085                                                         | Pass   | 13086    | Pass   | 13087    | Pass   | 13088    | Pass   |
| 13089                                                         | Pass   | 13090    | Pass   | 13091    | Pass   | 13092    | Pass   |
| 13093                                                         | Pass   | 13094    | Pass   | 13095    | Pass   | 13096    | Pass   |
| 13097                                                         | Pass   | 13098    | Pass   | 13099    | Pass   | 13100    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**