

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/133/26	Model No.: MARQ-6-50%	Date: 16-03-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 133/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 13201 To 13300 And 13205A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 13205A and removed from the Lot/Batch							
13201	Pass	13202	Pass	13203	Pass	13204	Pass
13205	Pass	13206	Pass	13207	Pass	13208	Pass
13209	Pass	13210	Pass	13211	Pass	13212	Pass
13213	Pass	13214	Pass	13215	Pass	13216	Pass
13217	Pass	13218	Pass	13219	Pass	13220	Pass
13221	Pass	13222	Pass	13223	Pass	13224	Pass
13225	Pass	13226	Pass	13227	Pass	13228	Pass
13229	Pass	13230	Pass	13231	Pass	13232	Pass
13233	Pass	13234	Pass	13235	Pass	13236	Pass
13237	Pass	13238	Pass	13239	Pass	13240	Pass
13241	Pass	13242	Pass	13243	Pass	13244	Pass
13245	Pass	13246	Pass	13247	Pass	13248	Pass
13249	Pass	13250	Pass	13251	Pass	13252	Pass
13253	Pass	13254	Pass	13255	Pass	13256	Pass
13257	Pass	13258	Pass	13259	Pass	13260	Pass
13261	Pass	13262	Pass	13263	Pass	13264	Pass
13265	Pass	13266	Pass	13267	Pass	13268	Pass
13269	Pass	13270	Pass	13271	Pass	13272	Pass
13273	Pass	13274	Pass	13275	Pass	13276	Pass
13277	Pass	13278	Pass	13279	Pass	13280	Pass
13281	Pass	13282	Pass	13283	Pass	13284	Pass
13285	Pass	13286	Pass	13287	Pass	13288	Pass
13289	Pass	13290	Pass	13291	Pass	13292	Pass
13293	Pass	13294	Pass	13295	Pass	13296	Pass
13297	Pass	13298	Pass	13299	Pass	13300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory