

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/100/26	Model No.: MARQ-6-50%	Date: 08-03-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 100/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 09901 To 10000 And 9905A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 9905A and removed from the Lot/Batch							
9901	Pass	9902	Pass	9903	Pass	9904	Pass
9905	Pass	9906	Pass	9907	Pass	9908	Pass
9909	Pass	9910	Pass	9911	Pass	9912	Pass
9913	Pass	9914	Pass	9915	Pass	9916	Pass
9917	Pass	9918	Pass	9919	Pass	9920	Pass
9921	Pass	9922	Pass	9923	Pass	9924	Pass
9925	Pass	9926	Pass	9927	Pass	9928	Pass
9929	Pass	9930	Pass	9931	Pass	9932	Pass
9933	Pass	9934	Pass	9935	Pass	9936	Pass
9937	Pass	9938	Pass	9939	Pass	9940	Pass
9941	Pass	9942	Pass	9943	Pass	9944	Pass
9945	Pass	9946	Pass	9947	Pass	9948	Pass
9949	Pass	9950	Pass	9951	Pass	9952	Pass
9953	Pass	9954	Pass	9955	Pass	9956	Pass
9957	Pass	9958	Pass	9959	Pass	9960	Pass
9961	Pass	9962	Pass	9963	Pass	9964	Pass
9965	Pass	9966	Pass	9967	Pass	9968	Pass
9969	Pass	9970	Pass	9971	Pass	9972	Pass
9973	Pass	9974	Pass	9975	Pass	9976	Pass
9977	Pass	9978	Pass	9979	Pass	9980	Pass
9981	Pass	9982	Pass	9983	Pass	9984	Pass
9985	Pass	9986	Pass	9987	Pass	9988	Pass
9989	Pass	9990	Pass	9991	Pass	9992	Pass
9993	Pass	9994	Pass	9995	Pass	9996	Pass
9997	Pass	9998	Pass	9999	Pass	10000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory