



Warranty Certificate

Date: 04-04-2026**Manufacturer:** Kanex Fire Solutions Limited.**Customer Name:** Indian Marketing & Services**Warranty Start Date:** 04-04-2026**Warranty End Date:** 03-04-2027.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	150	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice No. **26-27/K/000063 Dated: 04-04-2026 P.O.No. Mail-03-04-2026** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.

**Authorized Signatory**