

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/132/26	Model No.: MARQ-6-50%	Date: 16-03-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 132/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 13101 To 13200 And 13105A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 13105A and removed from the Lot/Batch							
13101	Pass	13102	Pass	13103	Pass	13104	Pass
13105	Pass	13106	Pass	13107	Pass	13108	Pass
13109	Pass	13110	Pass	13111	Pass	13112	Pass
13113	Pass	13114	Pass	13115	Pass	13116	Pass
13117	Pass	13118	Pass	13119	Pass	13120	Pass
13121	Pass	13122	Pass	13123	Pass	13124	Pass
13125	Pass	13126	Pass	13127	Pass	13128	Pass
13129	Pass	13130	Pass	13131	Pass	13132	Pass
13133	Pass	13134	Pass	13135	Pass	13136	Pass
13137	Pass	13138	Pass	13139	Pass	13140	Pass
13141	Pass	13142	Pass	13143	Pass	13144	Pass
13145	Pass	13146	Pass	13147	Pass	13148	Pass
13149	Pass	13150	Pass	13151	Pass	13152	Pass
13153	Pass	13154	Pass	13155	Pass	13156	Pass
13157	Pass	13158	Pass	13159	Pass	13160	Pass
13161	Pass	13162	Pass	13163	Pass	13164	Pass
13165	Pass	13166	Pass	13167	Pass	13168	Pass
13169	Pass	13170	Pass	13171	Pass	13172	Pass
13173	Pass	13174	Pass	13175	Pass	13176	Pass
13177	Pass	13178	Pass	13179	Pass	13180	Pass
13181	Pass	13182	Pass	13183	Pass	13184	Pass
13185	Pass	13186	Pass	13187	Pass	13188	Pass
13189	Pass	13190	Pass	13191	Pass	13192	Pass
13193	Pass	13194	Pass	13195	Pass	13196	Pass
13197	Pass	13198	Pass	13199	Pass	13200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory