

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/109/26	Model No.: MARQ-6-50%	Date: 09-03-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 109/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 10801 To 10900 And 10805A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 10805A and removed from the Lot/Batch							
10801	Pass	10802	Pass	10803	Pass	10804	Pass
10805	Pass	10806	Pass	10807	Pass	10808	Pass
10809	Pass	10810	Pass	10811	Pass	10812	Pass
10813	Pass	10814	Pass	10815	Pass	10816	Pass
10817	Pass	10818	Pass	10819	Pass	10820	Pass
10821	Pass	10822	Pass	10823	Pass	10824	Pass
10825	Pass	10826	Pass	10827	Pass	10828	Pass
10829	Pass	10830	Pass	10831	Pass	10832	Pass
10833	Pass	10834	Pass	10835	Pass	10836	Pass
10837	Pass	10838	Pass	10839	Pass	10840	Pass
10841	Pass	10842	Pass	10843	Pass	10844	Pass
10845	Pass	10846	Pass	10847	Pass	10848	Pass
10849	Pass	10850	Pass	10851	Pass	10852	Pass
10853	Pass	10854	Pass	10855	Pass	10856	Pass
10857	Pass	10858	Pass	10859	Pass	10860	Pass
10861	Pass	10862	Pass	10863	Pass	10864	Pass
10865	Pass	10866	Pass	10867	Pass	10868	Pass
10869	Pass	10870	Pass	10871	Pass	10872	Pass
10873	Pass	10874	Pass	10875	Pass	10876	Pass
10877	Pass	10878	Pass	10879	Pass	10880	Pass
10881	Pass	10882	Pass	10883	Pass	10884	Pass
10885	Pass	10886	Pass	10887	Pass	10888	Pass
10889	Pass	10890	Pass	10891	Pass	10892	Pass
10893	Pass	10894	Pass	10895	Pass	10896	Pass
10897	Pass	10898	Pass	10899	Pass	10900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory