

# HYDRO PRESSURE TEST

|                                   |                                                          |                  |
|-----------------------------------|----------------------------------------------------------|------------------|
| TC No.: HPT/F6/SP/RQ/004/26       | Model No.: KFMSRQ-6                                      | Date: 17-02-2026 |
| Type and Capacity of Extinguisher | : KFMSRQ-6-Kanex M Foam SP Fire Extinguisher Cap. 6 Ltr. |                  |
| Batch Number                      | : KFMSRQ6 004/26                                         |                  |
| Batch Quantity                    | : 11.00 Nos.                                             |                  |
| Serial Numbers                    | : 00031 To 40 And 35A                                    |                  |
| Month of Manufacturing            | : Feb/26                                                 |                  |

| Sr. Nos.                                                   | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 35A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 31                                                         | Pass   | 32       | Pass   | 33       | Pass   | 34       | Pass   |
| 35                                                         | Pass   | 36       | Pass   | 37       | Pass   | 38       | Pass   |
| 39                                                         | Pass   | 40       | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**