

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/044/26

Model No.: KFKHQ-6

Date: 24-03-2026

Type and Capacity of Extinguisher : KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.

Batch Number : KFKHQ6 044/26

Batch Quantity : 10 Nos.

Serial Numbers : 00431 To 440

Month of Manufacturing : Mar/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
431	Pass	432	Pass	433	Pass	434	Pass
435	Pass	436	Pass	437	Pass	438	Pass
439	Pass	440	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**