

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/086/26	Model No.: MARQ-6-40%	Date: 27-03-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 086/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 08501 To 8600 And 8505A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 8505A and removed from the Lot/Batch							
8501	Pass	8502	Pass	8503	Pass	8504	Pass
8505	Pass	8506	Pass	8507	Pass	8508	Pass
8509	Pass	8510	Pass	8511	Pass	8512	Pass
8513	Pass	8514	Pass	8515	Pass	8516	Pass
8517	Pass	8518	Pass	8519	Pass	8520	Pass
8521	Pass	8522	Pass	8523	Pass	8524	Pass
8525	Pass	8526	Pass	8527	Pass	8528	Pass
8529	Pass	8530	Pass	8531	Pass	8532	Pass
8533	Pass	8534	Pass	8535	Pass	8536	Pass
8537	Pass	8538	Pass	8539	Pass	8540	Pass
8541	Pass	8542	Pass	8543	Pass	8544	Pass
8545	Pass	8546	Pass	8547	Pass	8548	Pass
8549	Pass	8550	Pass	8551	Pass	8552	Pass
8553	Pass	8554	Pass	8555	Pass	8556	Pass
8557	Pass	8558	Pass	8559	Pass	8560	Pass
8561	Pass	8562	Pass	8563	Pass	8564	Pass
8565	Pass	8566	Pass	8567	Pass	8568	Pass
8569	Pass	8570	Pass	8571	Pass	8572	Pass
8573	Pass	8574	Pass	8575	Pass	8576	Pass
8577	Pass	8578	Pass	8579	Pass	8580	Pass
8581	Pass	8582	Pass	8583	Pass	8584	Pass
8585	Pass	8586	Pass	8587	Pass	8588	Pass
8589	Pass	8590	Pass	8591	Pass	8592	Pass
8593	Pass	8594	Pass	8595	Pass	8596	Pass
8597	Pass	8598	Pass	8599	Pass	8600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory