

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A50/RQ/013/26	Model No.: MARQ-9-50%	Date: 26-03-2026
Type and Capacity of Extinguisher	: MARQ-9-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg.	
Batch Number	: MARQ50%9 013/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 01201 To 1300 And 1205A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 1205A and removed from the Lot/Batch							
1201	Pass	1202	Pass	1203	Pass	1204	Pass
1205	Pass	1206	Pass	1207	Pass	1208	Pass
1209	Pass	1210	Pass	1211	Pass	1212	Pass
1213	Pass	1214	Pass	1215	Pass	1216	Pass
1217	Pass	1218	Pass	1219	Pass	1220	Pass
1221	Pass	1222	Pass	1223	Pass	1224	Pass
1225	Pass	1226	Pass	1227	Pass	1228	Pass
1229	Pass	1230	Pass	1231	Pass	1232	Pass
1233	Pass	1234	Pass	1235	Pass	1236	Pass
1237	Pass	1238	Pass	1239	Pass	1240	Pass
1241	Pass	1242	Pass	1243	Pass	1244	Pass
1245	Pass	1246	Pass	1247	Pass	1248	Pass
1249	Pass	1250	Pass	1251	Pass	1252	Pass
1253	Pass	1254	Pass	1255	Pass	1256	Pass
1257	Pass	1258	Pass	1259	Pass	1260	Pass
1261	Pass	1262	Pass	1263	Pass	1264	Pass
1265	Pass	1266	Pass	1267	Pass	1268	Pass
1269	Pass	1270	Pass	1271	Pass	1272	Pass
1273	Pass	1274	Pass	1275	Pass	1276	Pass
1277	Pass	1278	Pass	1279	Pass	1280	Pass
1281	Pass	1282	Pass	1283	Pass	1284	Pass
1285	Pass	1286	Pass	1287	Pass	1288	Pass
1289	Pass	1290	Pass	1291	Pass	1292	Pass
1293	Pass	1294	Pass	1295	Pass	1296	Pass
1297	Pass	1298	Pass	1299	Pass	1300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory