

HYDRO PRESSURE TEST

TC No.: HPT/A3/K/HQ/018/25	Model No.: KFKHQ-3	Date: 17-05-2025
Type and Capacity of Extinguisher	: KFKHQ-3-Kanex F Class Kitchen Fire Extinguisher Cap. 3 Ltr.	
Batch Number	: KFKHQ3 018/25	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00171 To 180 And 175A	
Month of Manufacturing	: May/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 175A and removed from the Lot/Batch							
171	Pass	172	Pass	173	Pass	174	Pass
175	Pass	176	Pass	177	Pass	178	Pass
179	Pass	180	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory