

HYDRO PRESSURE TEST

TC No.: HPT/MA2/A90/RQ/005/26	Model No.: MARQ-2-90%	Date: 26-03-2026
Type and Capacity of Extinguisher	: MARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: MARQ90%2 005/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 00401 To 500 And 405A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 405A and removed from the Lot/Batch							
401	Pass	402	Pass	403	Pass	404	Pass
405	Pass	406	Pass	407	Pass	408	Pass
409	Pass	410	Pass	411	Pass	412	Pass
413	Pass	414	Pass	415	Pass	416	Pass
417	Pass	418	Pass	419	Pass	420	Pass
421	Pass	422	Pass	423	Pass	424	Pass
425	Pass	426	Pass	427	Pass	428	Pass
429	Pass	430	Pass	431	Pass	432	Pass
433	Pass	434	Pass	435	Pass	436	Pass
437	Pass	438	Pass	439	Pass	440	Pass
441	Pass	442	Pass	443	Pass	444	Pass
445	Pass	446	Pass	447	Pass	448	Pass
449	Pass	450	Pass	451	Pass	452	Pass
453	Pass	454	Pass	455	Pass	456	Pass
457	Pass	458	Pass	459	Pass	460	Pass
461	Pass	462	Pass	463	Pass	464	Pass
465	Pass	466	Pass	467	Pass	468	Pass
469	Pass	470	Pass	471	Pass	472	Pass
473	Pass	474	Pass	475	Pass	476	Pass
477	Pass	478	Pass	479	Pass	480	Pass
481	Pass	482	Pass	483	Pass	484	Pass
485	Pass	486	Pass	487	Pass	488	Pass
489	Pass	490	Pass	491	Pass	492	Pass
493	Pass	494	Pass	495	Pass	496	Pass
497	Pass	498	Pass	499	Pass	500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory