

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/125/26	Model No.: KFARQ-6-50%	Date: 23-03-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 125/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 12401 To 12500 And 12405A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 12405A and removed from the Lot/Batch							
12401	Pass	12402	Pass	12403	Pass	12404	Pass
12405	Pass	12406	Pass	12407	Pass	12408	Pass
12409	Pass	12410	Pass	12411	Pass	12412	Pass
12413	Pass	12414	Pass	12415	Pass	12416	Pass
12417	Pass	12418	Pass	12419	Pass	12420	Pass
12421	Pass	12422	Pass	12423	Pass	12424	Pass
12425	Pass	12426	Pass	12427	Pass	12428	Pass
12429	Pass	12430	Pass	12431	Pass	12432	Pass
12433	Pass	12434	Pass	12435	Pass	12436	Pass
12437	Pass	12438	Pass	12439	Pass	12440	Pass
12441	Pass	12442	Pass	12443	Pass	12444	Pass
12445	Pass	12446	Pass	12447	Pass	12448	Pass
12449	Pass	12450	Pass	12451	Pass	12452	Pass
12453	Pass	12454	Pass	12455	Pass	12456	Pass
12457	Pass	12458	Pass	12459	Pass	12460	Pass
12461	Pass	12462	Pass	12463	Pass	12464	Pass
12465	Pass	12466	Pass	12467	Pass	12468	Pass
12469	Pass	12470	Pass	12471	Pass	12472	Pass
12473	Pass	12474	Pass	12475	Pass	12476	Pass
12477	Pass	12478	Pass	12479	Pass	12480	Pass
12481	Pass	12482	Pass	12483	Pass	12484	Pass
12485	Pass	12486	Pass	12487	Pass	12488	Pass
12489	Pass	12490	Pass	12491	Pass	12492	Pass
12493	Pass	12494	Pass	12495	Pass	12496	Pass
12497	Pass	12498	Pass	12499	Pass	12500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory