

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/087/26	Model No.: MARQ-6-40%	Date: 27-03-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 087/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 08601 To 8700 And 8605A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 8605A and removed from the Lot/Batch							
8601	Pass	8602	Pass	8603	Pass	8604	Pass
8605	Pass	8606	Pass	8607	Pass	8608	Pass
8609	Pass	8610	Pass	8611	Pass	8612	Pass
8613	Pass	8614	Pass	8615	Pass	8616	Pass
8617	Pass	8618	Pass	8619	Pass	8620	Pass
8621	Pass	8622	Pass	8623	Pass	8624	Pass
8625	Pass	8626	Pass	8627	Pass	8628	Pass
8629	Pass	8630	Pass	8631	Pass	8632	Pass
8633	Pass	8634	Pass	8635	Pass	8636	Pass
8637	Pass	8638	Pass	8639	Pass	8640	Pass
8641	Pass	8642	Pass	8643	Pass	8644	Pass
8645	Pass	8646	Pass	8647	Pass	8648	Pass
8649	Pass	8650	Pass	8651	Pass	8652	Pass
8653	Pass	8654	Pass	8655	Pass	8656	Pass
8657	Pass	8658	Pass	8659	Pass	8660	Pass
8661	Pass	8662	Pass	8663	Pass	8664	Pass
8665	Pass	8666	Pass	8667	Pass	8668	Pass
8669	Pass	8670	Pass	8671	Pass	8672	Pass
8673	Pass	8674	Pass	8675	Pass	8676	Pass
8677	Pass	8678	Pass	8679	Pass	8680	Pass
8681	Pass	8682	Pass	8683	Pass	8684	Pass
8685	Pass	8686	Pass	8687	Pass	8688	Pass
8689	Pass	8690	Pass	8691	Pass	8692	Pass
8693	Pass	8694	Pass	8695	Pass	8696	Pass
8697	Pass	8698	Pass	8699	Pass	8700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory