



Warranty Certificate

Date: 13-04-2026

Manufacturer: Kanex Fire Solutions Limited.

Customer Name: Goyam Impex LLPWarranty Start Date: 13-04-2026Warranty End Date: 12-04-2027.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KCARQ-2-Kanex Clean Agent HFC Based Fire Extinguisher Cap. 2 Kg.	1	As Per Annexure – I
2	KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	3	As Per Annexure – I
3	KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	2	As Per Annexure – I
4	KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.	1	As Per Annexure – I
5	KMCQRQ-2-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 2 Kg.	1	As Per Annexure – I
6	KMPRQ-5-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 5 Kg.	10	As Per Annexure – I
7	MARQ-9-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg.	1	As Per Annexure – I
8	MARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	3	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice No. **26-27/K/000322 Dated: 13-04-2026 P.O.No. GIL/PO/26-27/016** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.



Authorized Signatory

Corp. Off.: Office No.502, 5th Floor, A Wing, Damji Shamji Corporate Square, Ghatkopar -Andheri Link Road, Laxmi Nagar, Ghatkopar (E) Mumbai - 400 075 Tel : +91 022 2500 1288 E-mail : marketing@kanexfire.com