

HYDRO PRESSURE TEST

TC No.: HPT/MA2/A90/RQ/002/25	Model No.: MARQ-2-90%	Date: 07-02-2025
Type and Capacity of Extinguisher	: MARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: MARQ90%2 002/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 00101 To 200 And 105A	
Month of Manufacturing	: Feb/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 105A and removed from the Lot/Batch							
101	Pass	102	Pass	103	Pass	104	Pass
105	Pass	106	Pass	107	Pass	108	Pass
109	Pass	110	Pass	111	Pass	112	Pass
113	Pass	114	Pass	115	Pass	116	Pass
117	Pass	118	Pass	119	Pass	120	Pass
121	Pass	122	Pass	123	Pass	124	Pass
125	Pass	126	Pass	127	Pass	128	Pass
129	Pass	130	Pass	131	Pass	132	Pass
133	Pass	134	Pass	135	Pass	136	Pass
137	Pass	138	Pass	139	Pass	140	Pass
141	Pass	142	Pass	143	Pass	144	Pass
145	Pass	146	Pass	147	Pass	148	Pass
149	Pass	150	Pass	151	Pass	152	Pass
153	Pass	154	Pass	155	Pass	156	Pass
157	Pass	158	Pass	159	Pass	160	Pass
161	Pass	162	Pass	163	Pass	164	Pass
165	Pass	166	Pass	167	Pass	168	Pass
169	Pass	170	Pass	171	Pass	172	Pass
173	Pass	174	Pass	175	Pass	176	Pass
177	Pass	178	Pass	179	Pass	180	Pass
181	Pass	182	Pass	183	Pass	184	Pass
185	Pass	186	Pass	187	Pass	188	Pass
189	Pass	190	Pass	191	Pass	192	Pass
193	Pass	194	Pass	195	Pass	196	Pass
197	Pass	198	Pass	199	Pass	200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory