

TC No.: MA9/A40/RQ/002/26	Model No.: MARQ-9-90%	Date: 25-02-2026
Type and Capacity of Extinguisher	: MARQ-9-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg.	
Batch Number	: MARQ90%9 002/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 00101 To 200 And 105A	
Month of Manufacturing	: Feb/26	
Date of Inspection	: 25-02-2026	

Sr. Nos.	Cl. No.	Tests and Inspection	Requirements	Sampling	Observation
1	5.1.4	Extinguishing Agent	MAP 90% Dry Powder Conforms to IS 4308	One	Pass
2	5.2	Propellants	The propellants for stored pressure and cartridge operated extinguishers shall be air, carbon dioxide and nitrogen.	All	Nitrogen
3	5.3.2	Filling tolerance	±2% by Mass	One	Pass
4	6.1	Hydro test of the body	Test pressure 35 bar, Hold for 2.5 Min.	All	Pass
5	7.2	Effective discharge time	Approved fire rating is 6A:233B, hence Min. duration is 15sec. Sr. No. :00101	One	28 SEC.
6	7.2	Bulk range of Discharge	Approved fire rating is 6A:233B, hence Min. bulk range is 2m. Sr. No. :00101	One	6 Mtr.
7	3.8	Percentage of Discharge	Min. 85%, Sr. No. :00101	One	97%
8	7.4.1	Retention of Charge following partial discharge	The second pressure or weight shall not be less than 75% of the first after interruption of the discharge. Sr. No. :00102	One	95%
9	7.4.2	Leakage Test	Inverted Glass Jar/ Applying Soap Solution	All	Pass
10	9.2	Construction Requirements	As per IS 15683:2018	All	Pass
11	9.2.2	Burst test of body	Min. Burst pressure shall be 55 bar if break from body and shall be 80 bar if break from welding . Sr. No. :00105A	One	120 Bar
12	9.3	Carrying Handle	Requirements as per IS 15683:2018	All	Pass
13	9.4	Mounting Test	As per IS 15683:2018	All	Pass
14	9.5	Valves and Closures	As per IS 15683:2018	All	Pass
15	9.8	Hose Assemblies	Length of hose is 550mm and shall withstand a hydro pressure of 55 bar for at least 30 seconds.	One	65 Bar
16	9.9	Method of Operation	Max. force required to operate the valve with full hand is 200N	One	170N
17	9.10.1	Safety Locking Devices	Force required to remove safety locking device is 20N-100N	Two	70N & 75N
18	9.10.6	Safety Locking Devices	Tamper indicator shall break with force not more than 70N & other requirement as per IS 15683:2018	Two	60N & 65N
19	10.1	Color for body	Shade No. 538(P.O. Red) of IS 5 and blue band to be provided	All	Pass
20	--	Anticorrosive treatment & Painting	Phosphate treatment followed by Pure polyester Powder coating with DFT not less than 50μ.	All	(65-90)μ
21	10.2.1	Marking	As per IS 15683:2018	All	Pass
22	10.2.2	Operating Instructions	As per IS 15683:2018	All	Pass
23	10.2.3	Code symbols	As per IS 15683:2018	All	Pass
24	10.3	Inspection instruction	As per IS 15683:2018	All	Pass
25	Type tests	1)Resistance to Temp. changes 2)Impact test 3)Vibrations test 4)External Corrosion test 5)Tapping test 6)Intermittent discharge 7)Maximum Service Pressure 8)Crushing test 9)Pressure cycling 10)Fire performance test	As per IS 15683:2018	As per Scheme of testing	Pass
26	--	Dimensions and Completeness	Diameter: 180±5mm, Height: 575mm Approx, Thickness: 1.7mm Approx	All	Pass

Remarks: This is to certify that the ABC Dry Powder (Stored Pressure) type Fire Extinguisher of Capacity 9 kg. meets and conforms to the requirements of IS 15683:2018



Authorized Signatory