



Warranty Certificate

Date: 16-04-2026**Manufacturer:** Kanex Fire Solutions Limited.**Customer Name:** Technical Fire Protection Services.**Warranty Start Date:** 16-04-2026**Warranty End Date:** 15-04-2027.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KFCRQ-4.5-Kanex CO2 High Pressure Fire Extinguisher Cap. 4.5 Kg.	193	As Per Annexure – I
2	KFDRQ-50-S-Kanex DCP BC Dry Powder (SBC) Fire Extinguisher Cap. 50 Kg.	4	As Per Annexure – I
3	KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	15	As Per Annexure – I
4	KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	4	As Per Annexure – I
5	KFWRQ-45-Kanex Water Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	4	As Per Annexure – I
6	KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	37	As Per Annexure – I
7	KMPRQ-5-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 5 Kg.	8	As Per Annexure – I
8	MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	228	As Per Annexure – I
9	MMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr.	31	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice No. **26-27/K/000425 Dated: 16-04-2026 P.O.No. Mail-15-04-2026** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.

