

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A40/RQ/159/26     | Model No.: MARQ-6-50%                                          | Date: 27-03-2026 |
| Type and Capacity of Extinguisher | : MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ50%6 159/26                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 15801 To 15900 And 15805A                                    |                  |
| Month of Manufacturing            | : Mar/26                                                       |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 15805A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 15801                                                         | Pass   | 15802    | Pass   | 15803    | Pass   | 15804    | Pass   |
| 15805                                                         | Pass   | 15806    | Pass   | 15807    | Pass   | 15808    | Pass   |
| 15809                                                         | Pass   | 15810    | Pass   | 15811    | Pass   | 15812    | Pass   |
| 15813                                                         | Pass   | 15814    | Pass   | 15815    | Pass   | 15816    | Pass   |
| 15817                                                         | Pass   | 15818    | Pass   | 15819    | Pass   | 15820    | Pass   |
| 15821                                                         | Pass   | 15822    | Pass   | 15823    | Pass   | 15824    | Pass   |
| 15825                                                         | Pass   | 15826    | Pass   | 15827    | Pass   | 15828    | Pass   |
| 15829                                                         | Pass   | 15830    | Pass   | 15831    | Pass   | 15832    | Pass   |
| 15833                                                         | Pass   | 15834    | Pass   | 15835    | Pass   | 15836    | Pass   |
| 15837                                                         | Pass   | 15838    | Pass   | 15839    | Pass   | 15840    | Pass   |
| 15841                                                         | Pass   | 15842    | Pass   | 15843    | Pass   | 15844    | Pass   |
| 15845                                                         | Pass   | 15846    | Pass   | 15847    | Pass   | 15848    | Pass   |
| 15849                                                         | Pass   | 15850    | Pass   | 15851    | Pass   | 15852    | Pass   |
| 15853                                                         | Pass   | 15854    | Pass   | 15855    | Pass   | 15856    | Pass   |
| 15857                                                         | Pass   | 15858    | Pass   | 15859    | Pass   | 15860    | Pass   |
| 15861                                                         | Pass   | 15862    | Pass   | 15863    | Pass   | 15864    | Pass   |
| 15865                                                         | Pass   | 15866    | Pass   | 15867    | Pass   | 15868    | Pass   |
| 15869                                                         | Pass   | 15870    | Pass   | 15871    | Pass   | 15872    | Pass   |
| 15873                                                         | Pass   | 15874    | Pass   | 15875    | Pass   | 15876    | Pass   |
| 15877                                                         | Pass   | 15878    | Pass   | 15879    | Pass   | 15880    | Pass   |
| 15881                                                         | Pass   | 15882    | Pass   | 15883    | Pass   | 15884    | Pass   |
| 15885                                                         | Pass   | 15886    | Pass   | 15887    | Pass   | 15888    | Pass   |
| 15889                                                         | Pass   | 15890    | Pass   | 15891    | Pass   | 15892    | Pass   |
| 15893                                                         | Pass   | 15894    | Pass   | 15895    | Pass   | 15896    | Pass   |
| 15897                                                         | Pass   | 15898    | Pass   | 15899    | Pass   | 15900    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**