

# HYDRO PRESSURE TEST

|                                   |                                                         |                  |
|-----------------------------------|---------------------------------------------------------|------------------|
| TC No.: HPT/MM9/SP/RQ/010/26      | Model No.: MMSRQ-9                                      | Date: 09-03-2026 |
| Type and Capacity of Extinguisher | : MMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr. |                  |
| Batch Number                      | : MMSRQ9 010/26                                         |                  |
| Batch Quantity                    | : 101.00 Nos.                                           |                  |
| Serial Numbers                    | : 00901 To 1000 And 905A                                |                  |
| Month of Manufacturing            | : Mar/26                                                |                  |

| Sr. Nos.                                                    | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|-------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 905A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 901                                                         | Pass   | 902      | Pass   | 903      | Pass   | 904      | Pass   |
| 905                                                         | Pass   | 906      | Pass   | 907      | Pass   | 908      | Pass   |
| 909                                                         | Pass   | 910      | Pass   | 911      | Pass   | 912      | Pass   |
| 913                                                         | Pass   | 914      | Pass   | 915      | Pass   | 916      | Pass   |
| 917                                                         | Pass   | 918      | Pass   | 919      | Pass   | 920      | Pass   |
| 921                                                         | Pass   | 922      | Pass   | 923      | Pass   | 924      | Pass   |
| 925                                                         | Pass   | 926      | Pass   | 927      | Pass   | 928      | Pass   |
| 929                                                         | Pass   | 930      | Pass   | 931      | Pass   | 932      | Pass   |
| 933                                                         | Pass   | 934      | Pass   | 935      | Pass   | 936      | Pass   |
| 937                                                         | Pass   | 938      | Pass   | 939      | Pass   | 940      | Pass   |
| 941                                                         | Pass   | 942      | Pass   | 943      | Pass   | 944      | Pass   |
| 945                                                         | Pass   | 946      | Pass   | 947      | Pass   | 948      | Pass   |
| 949                                                         | Pass   | 950      | Pass   | 951      | Pass   | 952      | Pass   |
| 953                                                         | Pass   | 954      | Pass   | 955      | Pass   | 956      | Pass   |
| 957                                                         | Pass   | 958      | Pass   | 959      | Pass   | 960      | Pass   |
| 961                                                         | Pass   | 962      | Pass   | 963      | Pass   | 964      | Pass   |
| 965                                                         | Pass   | 966      | Pass   | 967      | Pass   | 968      | Pass   |
| 969                                                         | Pass   | 970      | Pass   | 971      | Pass   | 972      | Pass   |
| 973                                                         | Pass   | 974      | Pass   | 975      | Pass   | 976      | Pass   |
| 977                                                         | Pass   | 978      | Pass   | 979      | Pass   | 980      | Pass   |
| 981                                                         | Pass   | 982      | Pass   | 983      | Pass   | 984      | Pass   |
| 985                                                         | Pass   | 986      | Pass   | 987      | Pass   | 988      | Pass   |
| 989                                                         | Pass   | 990      | Pass   | 991      | Pass   | 992      | Pass   |
| 993                                                         | Pass   | 994      | Pass   | 995      | Pass   | 996      | Pass   |
| 997                                                         | Pass   | 998      | Pass   | 999      | Pass   | 1000     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**