

# HYDRO PRESSURE TEST

|                                   |                                                                        |                  |
|-----------------------------------|------------------------------------------------------------------------|------------------|
| TC No.: HPT/F45/RQ/017/26         | Model No.: KFMRQ-45                                                    | Date: 27-03-2026 |
| Type and Capacity of Extinguisher | : KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr. |                  |
| Batch Number                      | : KFMRQ45 017/26                                                       |                  |
| Batch Quantity                    | : 50.00 Nos.                                                           |                  |
| Serial Numbers                    | : 00801 To 850                                                         |                  |
| Month of Manufacturing            | : Mar/26                                                               |                  |

| Sr. Nos.                                                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|----------------------------------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on Cylinder Sr.No.505A and which is removed from the batch (11th batch) |        |          |        |          |        |          |        |
| 801                                                                                          | Pass   | 802      | Pass   | 803      | Pass   | 804      | Pass   |
| 805                                                                                          | Pass   | 806      | Pass   | 807      | Pass   | 808      | Pass   |
| 809                                                                                          | Pass   | 810      | Pass   | 811      | Pass   | 812      | Pass   |
| 813                                                                                          | Pass   | 814      | Pass   | 815      | Pass   | 816      | Pass   |
| 817                                                                                          | Pass   | 818      | Pass   | 819      | Pass   | 820      | Pass   |
| 821                                                                                          | Pass   | 822      | Pass   | 823      | Pass   | 824      | Pass   |
| 825                                                                                          | Pass   | 826      | Pass   | 827      | Pass   | 828      | Pass   |
| 829                                                                                          | Pass   | 830      | Pass   | 831      | Pass   | 832      | Pass   |
| 833                                                                                          | Pass   | 834      | Pass   | 835      | Pass   | 836      | Pass   |
| 837                                                                                          | Pass   | 838      | Pass   | 839      | Pass   | 840      | Pass   |
| 841                                                                                          | Pass   | 842      | Pass   | 843      | Pass   | 844      | Pass   |
| 845                                                                                          | Pass   | 846      | Pass   | 847      | Pass   | 848      | Pass   |
| 849                                                                                          | Pass   | 850      | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



**Authorized Signatory**