

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/131/26	Model No.: KFARQ-6-50%	Date: 27-03-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 131/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 13001 To 13100 And 13005A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 13005A and removed from the Lot/Batch							
13001	Pass	13002	Pass	13003	Pass	13004	Pass
13005	Pass	13006	Pass	13007	Pass	13008	Pass
13009	Pass	13010	Pass	13011	Pass	13012	Pass
13013	Pass	13014	Pass	13015	Pass	13016	Pass
13017	Pass	13018	Pass	13019	Pass	13020	Pass
13021	Pass	13022	Pass	13023	Pass	13024	Pass
13025	Pass	13026	Pass	13027	Pass	13028	Pass
13029	Pass	13030	Pass	13031	Pass	13032	Pass
13033	Pass	13034	Pass	13035	Pass	13036	Pass
13037	Pass	13038	Pass	13039	Pass	13040	Pass
13041	Pass	13042	Pass	13043	Pass	13044	Pass
13045	Pass	13046	Pass	13047	Pass	13048	Pass
13049	Pass	13050	Pass	13051	Pass	13052	Pass
13053	Pass	13054	Pass	13055	Pass	13056	Pass
13057	Pass	13058	Pass	13059	Pass	13060	Pass
13061	Pass	13062	Pass	13063	Pass	13064	Pass
13065	Pass	13066	Pass	13067	Pass	13068	Pass
13069	Pass	13070	Pass	13071	Pass	13072	Pass
13073	Pass	13074	Pass	13075	Pass	13076	Pass
13077	Pass	13078	Pass	13079	Pass	13080	Pass
13081	Pass	13082	Pass	13083	Pass	13084	Pass
13085	Pass	13086	Pass	13087	Pass	13088	Pass
13089	Pass	13090	Pass	13091	Pass	13092	Pass
13093	Pass	13094	Pass	13095	Pass	13096	Pass
13097	Pass	13098	Pass	13099	Pass	13100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory