

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/038/26

Model No.: KFKHQ-6

Date: 17-03-2026

Type and Capacity of Extinguisher : KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.

Batch Number : KFKHQ6 038/26

Batch Quantity : 10 Nos.

Serial Numbers : 00371 To 380

Month of Manufacturing : Mar/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
371	Pass	372	Pass	373	Pass	374	Pass
375	Pass	376	Pass	377	Pass	378	Pass
379	Pass	380	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**