

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/070/26	Model No.: KFARQ-6-90%	Date: 09-03-2026
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 070/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 06901 To 7000 And 6905A	
Month of Manufacturing	: Mar/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 6905A and removed from the Lot/Batch							
6901	Pass	6902	Pass	6903	Pass	6904	Pass
6905	Pass	6906	Pass	6907	Pass	6908	Pass
6909	Pass	6910	Pass	6911	Pass	6912	Pass
6913	Pass	6914	Pass	6915	Pass	6916	Pass
6917	Pass	6918	Pass	6919	Pass	6920	Pass
6921	Pass	6922	Pass	6923	Pass	6924	Pass
6925	Pass	6926	Pass	6927	Pass	6928	Pass
6929	Pass	6930	Pass	6931	Pass	6932	Pass
6933	Pass	6934	Pass	6935	Pass	6936	Pass
6937	Pass	6938	Pass	6939	Pass	6940	Pass
6941	Pass	6942	Pass	6943	Pass	6944	Pass
6945	Pass	6946	Pass	6947	Pass	6948	Pass
6949	Pass	6950	Pass	6951	Pass	6952	Pass
6953	Pass	6954	Pass	6955	Pass	6956	Pass
6957	Pass	6958	Pass	6959	Pass	6960	Pass
6961	Pass	6962	Pass	6963	Pass	6964	Pass
6965	Pass	6966	Pass	6967	Pass	6968	Pass
6969	Pass	6970	Pass	6971	Pass	6972	Pass
6973	Pass	6974	Pass	6975	Pass	6976	Pass
6977	Pass	6978	Pass	6979	Pass	6980	Pass
6981	Pass	6982	Pass	6983	Pass	6984	Pass
6985	Pass	6986	Pass	6987	Pass	6988	Pass
6989	Pass	6990	Pass	6991	Pass	6992	Pass
6993	Pass	6994	Pass	6995	Pass	6996	Pass
6997	Pass	6998	Pass	6999	Pass	7000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory